

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Hat Island Community
3616 Colby Ave - Box 335
Everett, WA 98201

Reference Number: 10-18989

Project: SHD-WWW - Hat Island Comm

System Name: HAT ISLAND COMMUNITY INC
System ID 31593N

Repeat Sample Number:

Lab Number: 164-42585

DOH Source Number: 00 - Distribution Sample (Bacteria)

Field ID: 1040066257

Sample Type: D - Drinking Water

Date Collected: 12/15/10 08:43

Sample Purpose: C - Compliance

Date Received: 12/16/10

Sample Location: G-106

Date Analyzed: 12/17/10 11:30

County: Snohomish

Report Date: 12/17/10

Sampled By: Orff

Comment: CI2:0.38

Sampler Phone: 360.444.6611

Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	sm	SM9223 B	
3	E. COLI	Absent	per 100mL		SM9223 B	

DEC 22 RECD

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Hat Island Community
3616 Colby Ave - Box 335
Everett, WA 98201

Reference Number: 10-18989

Project: SHD-WWW - Hat Island Comm

System Name: HAT ISLAND COMMUNITY INC
System ID 31593N

Repeat Sample Number:

Lab Number: 164-42585

DOH Source Number: 00 - Distribution Sample (Bacteria)

Field ID: 1040066257

Sample Type: D - Drinking Water

Date Collected: 12/15/10 08:43

Sample Purpose: C - Compliance

Date Received: 12/16/10

Sample Location: G-106

Date Analyzed: 12/17/10 11:30

County: Snohomish

Report Date: 12/17/10

Sampled By: Orff

Comment: CI2:0.38

Sampler Phone: 360.444.6611

Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	sm	SM9223 B	
3	E. COLI	Absent	per 100mL		SM9223 B	

DEC 22 RECD



If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp

WSDOH: <http://www.doh.wa.gov/eHP/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample. If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.