



Burlington WA  
Corporate Office

Bellingham WA  
Microbiology

Portland OR  
Microbiology/Chemistry

1620 S Walnut St - 98233  
800.755.9295 • 360.757.1400

805 W Orchard Dr Ste 4 - 98225  
360.671.0688

9150 SW Pioneer Ct Ste W- 97070  
503.682.7802

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Hat Island Community  
3616 Colby Ave - Box 335  
Everett, WA 98201

Reference Number: 11-03412

Project: SHD-WWW - Hat Island Comm

System Name: HAT ISLAND COMMUNITY INC

Repeat Sample Number:

System ID Number: 31593N

Lab Number: 164-07538

DOH Source Number: 00 - Distribution Sample (Bacteria)

Field ID: 1040066039

Sample Type: D - Drinking Water

Date Collected: 3/9/11 08:30

Sample Purpose: C - Compliance

Date Received: 3/10/11

Sample Location: G-106

Date Analyzed: 3/11/11 11:45

County: Snohomish


Report Date: 3/11/11

Sampled By: Orff

Comment:

Sampler Phone: 360.444.6611

Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>	per 100mL	slm	SM9223 B	m_110310	
3	E. COLI	<b>Absent</b>	per 100mL		SM9223 B	m_110310	
							

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample. If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.