



Burlington WA  
Corporate Office


1620 S Walnut St - 98233  
800.755.9295 • 360.757.1400

Bellingham WA  
Microbiology

805 Orchard Dr Ste 4 - 98225  
360.671.0688

Portland OR  
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W - 97070  
503.682.7802



## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

**Client Name:** Hat Island Community  
3616 Colby Ave #335  
Everett, WA 98201

**Reference Number:** 11-15556  
**Project:** Lead & Copper

**System Name:** HAT ISLAND COMMUNITY INC  
**System ID Number:** 31593N  
**DOH Source Number:** 93 - Standing Water (Pb&Cu)  
**Multiple Sources:**  
**Sample Type:** A - After treatment  
**Sample Purpose:** C - Compliance  
**County:** Snohomish

**Analyst:** bj  
**Date Received:** 9/27/2011  
**Report Date:** 10/13/2011

**Approved By:** *[Signature]*

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	MCL	SRL	METHOD	Comments
046-34518	9/26/2011	B-34	9	LEAD	0.001	mg/L	0.015	0.001	200.8	
			23	COPPER	0.440	mg/L	1.3	0.005	200.8	
046-34519	9/26/2011	G-81	9	LEAD	0.005	mg/L	0.015	0.001	200.8	
			23	COPPER	0.237	mg/L	1.3	0.005	200.8	
046-34520	9/26/2011	G-106	9	LEAD	0.001	mg/L	0.015	0.001	200.8	
			23	COPPER	0.385	mg/L	1.3	0.005	200.8	
046-34521	9/26/2011	M50	9	LEAD	0.004	mg/L	0.015	0.001	200.8	
			23	COPPER	0.275	mg/L	1.3	0.005	200.8	
046-34522	9/24/2011	G-51 Mukilteo Way	9	LEAD	ND	mg/L	0.015	0.001	200.8	
			23	COPPER	0.372	mg/L	1.3	0.005	200.8	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence Henderson at the above phone number.