

## HERBICIDES IN DRINKING WATER

Client Name: Hat Island Community  
3616 Colby Ave #335  
Everett, WA 98201

Reference Number: 10-16204

Project: Hat Island Community Inc

System Name: HAT ISLAND COMMUNITY INC  
System ID Number: 31593N  
DOH Source Number: 07  
Multiple Sources:  
Sample Type: A - After treatment  
Sample Purpose: C - Compliance  
Sample Location: G-Tank  
County: Snohomish  
Sampled By: Wayne Orff  
Sampler Phone: 360-444-6611

Field ID: Hat Island Comm.  
Lab Number: 046-36256  
Date Collected: 10/20/10 08:50  
Date Extracted: 515.4\_101028  
Date Analyzed: 11/01/10  
Report Date: 11/4/10  
Analyst: CO  
Peer Review: *pm*

### EPA Method 515.4 For State Drinking Water Compliance

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	COMMENT
<b>EPA Regulated</b>							
37	*2,4 - D	ND	ug/L	0.5	0.2	70	
38	*2,4,5 - TP (SILVEX)	ND	ug/L	1.0	0.4	50	
134	*PENTACHLOROPHENOL	ND	ug/L	0.2	0.08	1	
137	*DALAPON	ND	ug/L	5	2	200	
139	*DINOSEB	ND	ug/L	1.0	0.4	7	
140	*PICLORAM	ND	ug/L	0.5	0.2	500	
<b>Other</b>							
138	*DICAMBA	ND	ug/L	0.2	0.2		
225	*DCPA (ACID METABOLITES)	ND	ug/L	0.1	0.1		
135	*2,4 DB	ND	ug/L	1.0	1.0		
136	*2,4,5 T	ND	ug/L	0.4	0.4		
220	*BENTAZON	ND	ug/L	0.5	0.5		
221	*DICHLORPROP	ND	ug/L	0.5	0.5		
223	*ACIFLUORFEN	ND	ug/L	2.0	2.0		
226	*3,5 - DICHLOROBENZOIC ACID	ND	ug/L	0.5	0.5		

**NOTES:**  
If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.  
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; a blank MCL value indicates a level is not currently established.

Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
ND (Not Detected): indicates that the parameter was not detected above the State Reporting Limit (SRL).  
An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
If you have any questions concerning this report contact Lawrence Henderson at the above phone number.