



Burlington, WA Corporate Laboratory (a) 1620 S Walnut St Burlington, WA 98233 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b) 805 Orchard Dr Ste 4 Bellingham, WA 98225 360.715.1212
 Portland, OR Microbiology/Chemistry (c) 9150 SW Pioneer Ct Ste W Wilsonville, OR 97070 503.682.7802
 Corvallis, OR Microbiology (d) 540 SW Third Street Corvallis, OR 97333 541.753.4946



FL NELAP E871040

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island Community
 3616 Colby Ave - Box 335
 Everett, WA 98201

Reference Number: 17-37826
 Project: SHD-WWW - Hat Island Commur

System Name: HAT ISLAND COMMUNITY INC
 System ID Number: 31593N
 DOH Source Number: 07

Sample Number: 1040161472
 Lab Number: 046-81594
 Collect Date: 12/20/17 10:00

Multiple Sources:
 Sample Type: A - After treatment
 Sample Purpose: C - Compliance

Date Received: 12/21/17
 Report Date: 1/5/18
 Sampled By: CHRIS INMAN

Sample Location: G TANK PUMP HOUSE (PRE DISTRIBUTION)
 County: SNOHOMISH

Sampler Phone: 208-283-6443

Approved by: anp

Authorized by:

Patrick Miller
 Patrick Miller, MS
 QA Officer

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.006	mg/L	0.001		0.010	bj	200.8	a	01/03/18	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.