



Burlington, WA	Corporate Laboratory (a)	1529 S Walnut St	Burlington, WA 98233	808.755.8295 • 360.757.1498
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4846



OR NELAP 4072

## INORGANIC COMPOUNDS (IOC) REPORT

**Client Name:** Snohomish Health District - WWW  
 3616 Colby Ave PMB 335  
 Everett, WA 98201

**Reference Number:** 19-02069  
**Project:** SHD-WWW-Hat Island

**Date Collected:** 1/16/19 14:00  
**System ID Number:** 31593N  
**Lab Number:** 046-04490  
**Sample Location:** Arsenic Sample  
**Sample Purpose:** C - Compliance  
**Sample Composition:** Single Source  
**Approved by:** anp  
**Authorized by:**

*Patrick Miller*  
 Patrick Miller, MS  
 QA Officer

**Field ID:** 1040183649  
**System Group Type:** A  
**System Name:** HAT ISLAND COMMUNITY INC  
**County:** Snohomish  
**Source Number:** 07  
**Multiple Sources:**  
**Date Received:** 1/17/19  
**Report Date:** 1/25/19  
**Sample Type:** D - Drinking Water  
**Sampled By:** Chris F  
**Sampler Phone:**

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	<b>EPA Regulated</b> ARSENIC	<b>0.004</b>	mg/L	0.001		0.010	bj	200.8	a	01/24/19	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
 If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.