



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name:

3616 Colby Ave - Box 335  
Everett, WA 98201

Reference Number: 18-35619

Project: SHD-WWW - Hat Island  
Community Water

System Name: HAT ISLAND COMMUNITY INC

System ID Number: 31593N

Repeat Sample Number:

Lab Number: 164-72141

DOH Source Number: 00 - Distribution Sample (Bacteria)

Field ID: 1040174847

Sample Type: D - Drinking Water

Date Collected: 9/19/18 09:00

Sample Purpose: C - Compliance

Date Received: 9/20/18

Sample Location: B-38

Date Set: 9/20/18 12:13

County: Snohomish

Date Analyzed: 9/21/18 8:59

Sampled By: CHRIS

Report Date: 9/21/18

Sampler Phone: 3604446611

Comment:

Approved By: ckk,rml

Authorized by:

Ceann K Knox  
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	ckk	SM9223 B	m_180920a	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_180920a	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>

San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>

Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380

Snohomish Co: 425-339-5250

Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)

WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.  
\*If data qualifiers are present, see accompanying Qualifier Definition report.