



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212


Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island
 3616 Colby Ave - Box 335
 Everett, WA 98201

Reference Number: 19-46159
 Project: SHD-WWW - Hat Island Commur

Date Collected: 12/4/19 11:00
 System ID Number: **31593N**
 Lab Number: **046-89310**
 Sample Location: B-38
 Sample Purpose: C - Compliance
 Sample Composition: Single Source
 Approved by: ajw
 Authorized by: 
 Patrick Miller, MS
 QA Officer

Field ID: 1040192705
 System Group Type: A
 System Name: HAT ISLAND COMMUNITY INC
 County: Snohomish
 Source Number: **07**
 Multiple Sources: Wells 1,2,3,5,6
 Date Received: 12/5/19
 Report Date: 12/10/19
 Sample Type: D - Drinking Water
 Sampled By: Chris Inman
 Sampler Phone: 3604446611

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	ND	mg/L	0.001		0.010	bj	200.8	a	12/09/19	

NOTES:
 SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.
 These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Patrick Miller, MS, QA Officer, at the toll-free phone number above.