



Burlington, WA Corporate Laboratory (a)  
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400  
 Bellingham, WA Microbiology (b)  
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)  
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802  
 Corvallis, OR Microbiology/Chemistry (d)  
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946  
 Bend, OR Microbiology (e)  
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

## INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island Community  
 3616 Colby Ave #335  
 Everett, WA 98201

Reference Number: 20-19117  
 Project: Arsenic

Date Collected: 6/10/20 13:00  
 System ID Number: **31593N**  
 Lab Number: **046-36685**  
 Sample Location: G-Tank  
 Sample Purpose: C - Compliance  
 Sample Composition: Single Source

Field ID:  
 System Group Type: A  
 System Name: HAT ISLAND COMMUNITY INC  
 County: Snohomish  
 Source Number: **07**  
 Multiple Sources:  
 Date Received: 6/11/20  
 Report Date: 6/17/20  
 Sample Type: U - Unknown  
 Sampled By: Chris Inman  
 Sampler Phone: 360-444-6611

Approved by: ajw  
 Authorized by:

Lawrence J Henderson, PhD  
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	<b>EPA Regulated</b> ARSENIC	<b>0.0059</b>	mg/L	0.001		0.010	bj	200.8	a	06/15/20	

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.