



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Hat Island Community
3616 Colby Ave #335
Everett, WA 98201

Reference Number: 20-35661
Project: Arsenic

Date Collected: 10/6/20 13:00
System ID Number: **31593N**
Lab Number: **046-67754**
Sample Location: G Tank Pump House (Pre Distribution)
Sample Purpose: C - Compliance
Sample Composition: Single Source

Approved by: bsp

Authorized by:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Field ID:
System Group Type: A
System Name: HAT ISLAND COMMUNITY INC
County: SNOHOMISH
Source Number: **07**
Multiple Sources:
Date Received: 10/7/20
Report Date: 10/16/20
Sample Type: B - Before treatment
Sampled By: Chris Inman
Sampler Phone: 208-283-6443

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
4	EPA Regulated ARSENIC	0.0056	mg/L	0.001		0.010	bj	200.8	a	10/09/20	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.