



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Hat Island Community**
3616 Colby Ave #335
Everett, WA 98201

Reference Number: 20-12021
Project: Hat Island Bacteria

System Name: HAT ISLAND COMMUNITY INC
System ID Number: 31593N
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: HI Office
County: Snohomish
Sampled By: Chris Inman
Sampler Phone: 360-444-6611

Repeat Sample Number:
Lab Number: 164-23371
Field ID: Hat Island
Date Collected: 4/8/20 13:00
Date Received: 4/9/20
Date Set: 4/9/20 11:53
Date Analyzed: 4/10/20 9:34
Report Date: 4/10/20
Comment:
Approved By: ckk,rml

Authorized by:

Ceann K Knox
Lab Manager, Bellingham

| DOH# | PARAMETER | RESULT | Qualifier | UNITS | Analyst | METHOD | Batch | COMMENT |
|------|----------------|---------------------------------------|-----------|-----------|---------|----------|-----------|---------|
| 1 | TOTAL COLIFORM | Satisfactory, Coliforms Absent | | per 100mL | jln | SM9223 B | m_200409a | |
| 3 | E. COLI | Absent | | per 100mL | | SM9223 B | m_200409a | |

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.