



Burlington, WA *Corporate Laboratory (a)*
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400
 Bellingham, WA *Microbiology (b)*
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR *Microbiology/Chemistry (c)*
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR *Microbiology/Chemistry (d)*
 1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946
 Bend, OR *Microbiology (e)*
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425




Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Hat Island Community**
 3616 Colby Ave #335
 Everett, WA 98201

Reference Number: 20-19273
 Project: Hat Island Bacteria

System Name: HAT ISLAND COMMUNITY INC
 System ID Number: 31593N
 DOH Source Number: 00 - Distribution Sample (Bacteria)
 Sample Type: D - Drinking Water
 Sample Purpose: C - Compliance
 Sample Location: B-38
 County: Snohomish
 Sampled By: Chris Inman
 Sampler Phone: 360-444-6611

Repeat Sample Number:
 Lab Number: 164-36940
 Field ID: Hat Island
 Date Collected: 6/10/20 13:00
 Date Received: 6/11/20
 Date Set: 6/11/20 12:06
 Date Analyzed: 6/12/20 16:03
 Report Date: 6/15/20
 Comment:
 Approved By: ckk,rml

Authorized by: 
 Ceann K Knox
 Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	jln	SM9223 B	m_200611s1	
3	E. COLI	Absent		per 100mL		SM9223 B	m_200611s1	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory, three (3) repeat samples and groundwater source samples are required for Group A Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.

If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.

*If data qualifiers are present, see accompanying Qualifier Definition report.