



Burlington, WA	Corporate/Laboratory (H)	1620 S Walnut St	Burlington, WA 98223	800.755.6295 - 360.757.1400
Bellingham, WA	Microbiology (H)	805 Crooked Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (H)	5150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (H)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



TEL NELAP E071040

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: Snohomish Health District
 3020 Rucker Ave Ste 104
 Everett, WA 98201

System Name: HAT ISLAND COMMUNITY INC
 System ID Number: 31593N
 DOH Source Number: 08

Multiple Sources:
 Sample Type: A - After treatment
 Sample Purpose: C - Compliance
 Sample Location: RO Bldg. Pre-distribution
 County: SNOHOMISH

Reference Number: 17-20818
 Project: SHD-WWW - Hat Island Commun

Sample Number: 1040152096, 1040152097
 Lab Number: 156-46571
 Collect Date: 8/15/17 13:00
 Date Received: 8/16/17
 Report Date: 10/5/17
 Sampled By: Chris Inman
 Sampler Phone: 208-283-6443
 Approved by: *fm*
 Authorized by: *[Signature]*

[Signature]
 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
	Radiological										
	RADIUM 226	ND	pCi/L	1			jlw	904.0		08/15/17	Analyzed by Pace
	GROSS ALPHA	ND	pCi/L	3		15	meq	900.0		08/15/17	Analyzed by Pace
	GROSS BETA	ND	pCi/L	4		50	meq	900.0		08/15/17	Analyzed by Pace

NOTES:
 SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
 An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.
 These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.
 If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.