



Burlington, WA Corporate Laboratory (a)
1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 • 360.757.1400

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
1100 NE Circle Blvd, Ste 130 - Corvallis, OR 97330 - 541.753.4946

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



OR NELAP 4072

Page 1 of 1

LEAD & COPPER RULE REPORT

Client Name: Hat Island Community
3616 Colby Ave #335
Everett, WA 98201

Reference Number: 20-25504

Project: Lead & Copper Rule

System ID Number: **31593N**
Lab Number: 046-48384
Sample Purpose: C - Compliance
Sample Composition: Single Source

Field ID:
System Group Type: A
System Name: HAT ISLAND COMMUNITY INC
County: SNOHOMISH
Source Number: 93 - Standing Water (Pb&Cu)
Multiple Sources:
Date Received: 7/29/2020
Date Reported: 8/6/20
Sample Type: A - After treatment
Sample Collected By: Chris Inman
Sampler Phone:

Approved By: ljh

Authorized By:

Lawrence J Henderson, PhD
Director of Laboratories, Vice President

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
046-48384	7/28/2020	- 38 B Whidbey Island Dr.	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/3/20	
			23	COPPER	0.160	mg/L	1.3	0.005	200.8	a	8/3/20	
046-48385	7/28/2020	- J-36 Everett Way	9	LEAD	0.001	mg/L	0.015	0.001	200.8	a	8/3/20	
			23	COPPER	0.267	mg/L	1.3	0.005	200.8	a	8/3/20	
046-48386	7/28/2020	- Hat Island Office Apt.	9	LEAD	0.001	mg/L	0.015	0.001	200.8	a	8/3/20	
			23	COPPER	0.118	mg/L	1.3	0.005	200.8	a	8/3/20	
046-48387	7/28/2020	- M055 Whidbey Isl Dr.	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	8/3/20	
			23	COPPER	0.075	mg/L	1.3	0.005	200.8	a	8/3/20	
046-48388	7/28/2020	- 24 F Saratoga Dr.	9	LEAD	0.001	mg/L	0.015	0.001	200.8	a	8/3/20	
			23	COPPER	0.134	mg/L	1.3	0.005	200.8	a	8/3/20	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.